



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 11/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	14:15:00 15:00:00 17:30:00	14:20:00 15:05:00 17:35:00	
2	OHP	CO-26	TRIPPED ON OLR	RESET DONE	16:50:00 19:00:00 20:55:00	16:59:00 19:10:00 21:05:00	
3	OHP	CO -26 WBR	SLEW NOT WORKING	DRIVE TRIPPED .... RESET DONE	16:35:00	16:50:00	
4	OHP	CO-51 CD	TRIPPED	RESET DONE	14:50:00	15:20:00	
5	OHP	CO-67	TRIPPED ON OLR	RESET DONE	16:00:00 20:15:00	16:15:00 20:30:00	
6	OHP	CO-16	TRIPPED ON OLR	RESET DONE	20:00:00 20:10:00	20:10:00 20:20:00	
7	CHP	CC-37 SCR-7	SLEW NOT WORKING	ABC TRIPPED ... RESET DONE AND TESTED	14:45:00	14:55:00	
8	CHP	CC-105 SCR-10	LT NOT WORKING	PCRD CABLE FALLEN .. GUIDE ALSO PROBLEM ... RECTIFIED WITH MECHANICAL	16:00:00	16:20:00	
9	CHP	CC-203	TRIPPED ON OLR	RESET DONE	17:05:00	17:10:00	
10	CHP	CC-15	C/S ACTED ... CABLE CUT	JOINT DONE	18:45:00	18:55:00	
11	CHP	CC-54	TRIPPED ON OLR	RESET DONE	15:20:00 18:40:00	15:30:00 18:50:00	