



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/02/2026

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-15	ZSS acting	Cage bearing problem.Replaced and tested okay	16:36:00	17:00:00	
2	OHP	VS-2	Reported tripped	OLR acted.Reset done	19:15:00	19:20:00	
3	CHP	CC-54	Reported tripped	OLR acted.Reset done(5 times)	14:40:00	20:00:00	
4	CHP	CC-51	MPD tripped	Reset done	20:20:00	20:25:00	
5	CHP	CC-203	Reported tripped	OLR acted.Reset done	14:20:00	14:30:00	
6	CHP	CC-32 SCR-5	Lt not taking place	M4 tripped.Reset done	14:50:00	15:00:00	
7	CHP	CC-31 SCR-4	LT not taking place	PCRD tension acted.Released and tested okay	14:55:00	15:05:00	
8	CHP	CC-40 SCR-2	Slew not taking place	wrong complaint	18:50:00	18:55:00	
9	CHP	Cc-216	Reported tripped	OLR acted.Reset done	20:00:00	20:05:00	
10	CHP	CC-7	Reported C/S not healthy	High found loose at CJB.tightened and tested okay	16:11:00	16:25:00	
11	CHP	CC-14	Reported not healthy	OLR acted.Reset done	16:20:00	16:25:00	
12	CHP	Cc-28	Reported tripped	OLR acted.Reset done(2 times)	14:00:00	16:45:00	
13	WT	OP-5	Reported not moving	Pusher found at dead end.Jumpers laid and pusher moved forward.	21:10:00	21:40:00	