



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/11/2025

Area: CHP

| Equipment | Job |
|------------------------|--|
| CC 7 tunnel | 6 nos 70W SV fixtures provided |
| CC 54 gallery | Lighting improved |
| Elec store | Cleaning done |
| CC 222 VFD | Parameters adjusted and trail run was taken |
| SCR 4 | PCRD layring inspected and found ok |
| CC 222 | T/E lighting improved . Provided 2nos 120W and 4 nos 70W fixtures |
| S 3 | LT potentiometer replaced and tested |
| CC 35, SCR 3,8, CC 115 | PPM was done |
| CC 213 mast | Clamps welded as per CME requirement. Get the cleaning done around the mast area |