



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 31/05/2025

Area: OHP

| Equipment | Job |
|--------------------|--|
| losp-1 and locp-1 | sb levels ppm is done. |
| JH O-3 hoist | hoist motor supply problem is rectified, load trail is done, brake is not acting properly, mechanical is informed. |
| running inspection | running inspection of co-77 and co-29 , brc-1 and brc-3 is done |
| tbs-3 shifting | shifted form co-7a to 21 |
| tbs-1 shifting | shifted from co-21 to 7a |
| tbs on co-24 | ppm is done |
| hoists ppm | co-59 ,bpc-1, bpc-2, 27a,30a,31a,33a,35a,37a,38b,65 h/e hoists ppm is done |