



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 13/11/2025

Area: OHP

Equipment	Job
tbs- on repair bay	rbc motor termination is done and zss cable is laid.,
brc 5 on co-32	festoon cable cleaned and maintenance is done ; bridge conveyor motor earth jumper is provided.
tbs-2 on oc-22	pcrd resistance box cleaned;
co-86 head end ; 77,78 gallery	illumination is improved
co-77,84,86 and their hoists	motor and panel side ppm is done
co-13a, 42a ,14b,16a ,11a,vs-1a level gallery, ;	illumination is improved
daybins-2 ; 11a,12a, cbms- on co-11a hoists	hoists ppm is done
reclaiming streams	cjd's ppm is done