



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/12/2025

Incharge(s): Amit Roy

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|------------------------------|---|----------|----------|-----------------------|
| 1 | OHP | CO-25 | Reported tripped | OLR acted.Reset done | 02:50:00 | 03:00:00 | |
| 2 | OHP | CO-85 | Reported tripped | OLR acted.Reset done | 02:45:00 | 02:50:00 | |
| 3 | OHP | CO-26 | Reported tripped | OLR acted.Reset done(3 times) | 22:10:00 | 05:25:00 | |
| 4 | OHP | CO-10A | Reported ZSS acting | Checked and found Probe insulation damaged.Insulated properly and tested okay | 00:40:00 | 01:00:00 | |
| 5 | OHP | Cr-2A | Reported ZSS acting | Probe gap adjusted and tested okay | 04:30:00 | 05:00:00 | |
| 6 | CHP | Cc-15 | Reported ZSS acting | Belt through cut found. | 05:00:00 | 05:10:00 | Informed to operation |
| 7 | WT | OP-9 | Emergency acted at Dead end | Released and tested okay | 22:35:00 | 22:50:00 | |
| 8 | IOSA | BRC | Reported CT not taking place | Ct limit handle damaged.handle replaced and tested okay | 01:35:00 | 01:50:00 | |