



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/04/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 20	RBC NOT RUNNING BELT SLIPPED DUE TO JAMMING	INFORMED TO OPERATION	15:25:00	15:35:00	
2	OHP	WOBR ON CO 26	SLEWING NOT TAKING PLACE DRIVE TRPPED	RESET	15:40:00	16:00:00	
3	OHP	TBS ON CO 22	LBC STOPPING ON ZS PROBE DAMAGED	PROBE REPLASD	15:45:00	16:15:00	
4	OHP	TIS ON CO 29	ZS PROBE DAMAGED	PROBE REPLACED	17:00:00	17:30:00	
5	OHP	CO34	OLR ACTED	RESET	18:00:00 18:15:00	18:05:00 18:30:00	
6	OHP	CO33M	OLR ACTED	RESET	19:00:00	19:10:00	
7	OHP	WOBR ON CO25	LT NOT TAKING PLACE MAIN CONTROL OFF	CONTROL ON	19:30:00	19:35:00	
8	OHP	WOBR ON CO 25	B/C STOPPING ZS PROBE DAMAGED	PROBE REPLACED	19:40:00	20:00:00	
9	OHP	CO6A	BRS NOT RESETTING	BY PASSED	21:00:00	21:30:00	JOD IN LINE
10	CHP	CC104 SCR 9	SLEWING NOT WORKING DRIVE TRPPED	RESET	16:35:00	16:45:00	
11	CHP	CC34 SCR 2	B/C STOPPING FREQUENTLY SIGNAL PROBLEM	INFORMED TO OPERATION	19:00:00	20:00:00	
12	CHP	CC36	ZS PROBLEM	PROBE CHANGED	21:15:00	21:30:00	
13	IOSA	OC 7A	NOT RUNNING HVMCC 5 I/C 1 TRIPPED	MADE ON	18:45:00	19:15:00	