



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/08/2025

Incharge(s): Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 15	OLR acted	reset done	14:50:00	15:00:00	
2	OHP	CO 113	OLR acted	reset done	14:50:00	15:00:00	
3	OHP	WOBR on CO 29	BC not running	control supply tripped due to luff up limit acted, luff down then okay	19:30:00	20:00:00	
4	OHP	CO 19	OLR acted	reset done	19:40:00	19:50:00	
5	OHP	CO 29	OLR acted	reset done	21:30:00	21:40:00	
6	CHP	CC 34 , SCR 2	LT not working	OT acted , released	16:00:00	16:20:00	
7	CHP	CC 38 , SCR 6	BC not working	BC jamming and OLR acted. Reset done	16:30:00	16:50:00	
8	CHP	CC 105 , SCR 7	Slew not working	Break fail alarm reset	19:00:00	19:30:00	
9	CHP	CC 104 , SCR 9	BC signal missing	LT done	20:30:00	20:55:00	