



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 07/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	22:20:00	22:30:00	
2	OHP	BRC ON CO 8A	24 V MISSING TO XMD PANEL SOME TIMES WHILE RUNNING AND PUMP STOPPING	HYDRAULIC INTERLOCKS BYPASSED MADE IT RUN	23:00:00	03:00:00	FESTON CABLE LOOPS AND CHAIN ALSO ADJUSTED
3	CHP	CC 29 ON CC 33	POSITION BIT LOOSE IN I/O RACK	TIGHTENED	22:30:00	22:45:00	
4	CHP	R1 ON CC 32 B/C	INTERLOCK CAGE STUCK	MADE IT FREE	02:00:00	02:15:00	
5	CHP	CC 105 SCR 10	LT PCRD O/T ACTED	RELEASED	04:00:00	04:15:00	
6	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:00:00	05:30:00	12 TIMES
7	CHP	CC 131	OLR ACTED	RESET	00:45:00	00:50:00	
8	CHP	CC 54	OLR ACTED	RESET	05:55:00	06:00:00	
9	CHP	CC 52	FEEDING CONV OLR ACTED	RESET	05:20:00	05:25:00	
10	CHP	CC 130	DRIVE TRIP	RESET	00:55:00	01:05:00	
11	WT	CO 3	OLR ACTED	RESET	04:15:00 04:25:00	04:20:00 04:30:00	