



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|--|----------|----------|---------------------------|
| 1 | OHP | CO 37A | STOPPING ON ZS CAGE STUCK UP | ZS CAGE REPLACED | 09:30:00 | 09:45:00 | |
| 2 | OHP | TBS ON CO 21 | LEFT B/C STOPPING ON ZS PROBE DAMAGED | ZS PROBE REPLACED | 10:30:00 | 10:45:00 | |
| 3 | OHP | CO 84 | OLR ACTED | RESET | 08:40:00 | 08:50:00 | |
| 4 | OHP | BRC ON CO 34 | B/W S NOT RUNNING CP 1 TRIP | RESET | 12:10:00 | 12:30:00 | |
| 5 | CHP | cc 32 scr 5 | B/C STOP in ZSS,cage problem | ZSS cage replaced | 07:20:00 | 07:30:00 | |
| 6 | CHP | CC 38 SCR3 | b/c stop in ZSS,cage and module problem | ZSS cage and module replaced | 08:00:00 | 08:15:00 | |
| 7 | CHP | CC 105 SCR 10 | b/c not running,zss acted,coal stucked in ZSS cage,machine at tail end and scr 9 inbetween CCR | zss cage made free and LT done than ok | 10:55:00 | 11:10:00 | |
| 8 | CHP | CC 105 SCR 10 | B/C not running,control mcb trip | control mcb made on | 11:35:00 | 11:50:00 | |
| 9 | CHP | CC 114 | OLR ACTED | RESET | 07:30:00 | 07:40:00 | DUE TO MATERIAL OVER LOAD |
| 10 | CHP | CC 131 | OLR ACTED(3TIMES) | RESET | 08:10:00 | 08:15:00 | |
| 11 | CHP | CC 54 | OLR ACTED(2TIMES) | RESET | 08:10:00 | 08:30:00 | |
| 12 | CHP | CC 58 | OLR ACTED | RESET | 08:50:00 | 09:10:00 | |
| 13 | CHP | cc 112 | D/E CJS not healthy probe touched body | probe adjusted | 12:55:00 | 13:10:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------|-------------------------------|----------------------|----------|----------|---------|
| 14 | CHP | CC 18 | cjs acted, | sensor cleaning done | 07:00:00 | 07:10:00 | |
| 15 | CHP | CC 25 | mech BRS acted | informed mech | 07:30:00 | 07:45:00 | |
| 16 | CHP | CC 34 SCR 2 | LT not working, PCRD OT acted | OT released | 13:10:00 | 13:20:00 | |