



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/07/2025

Area: CHP

Equipment	Job
CC 53	BSS cable replaced and kept in ckt
CC 58	Lighting improved
JH C 3	Hoist panels maintenance was done
CC 26	PPM was done
SCR 8	Cable removal job under progress
CC 222	VFD drive panel replaced and trail run was taken