



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/07/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|-----------------------------------|----------|----------|---------|
| 1 | OHP | CO 21 | stop in ZSS fault,zss cage module ok,belt slipping | informed operation and mech | 08:45:00 | 08:55:00 | |
| 2 | OHP | BRC on 34 | LT not working,wrong complaint | checked LT working ok | 07:45:00 | 08:00:00 | |
| 3 | OHP | RSCO 9A | olr acted | reset | 10:30:00 | 10:40:00 | |
| 4 | CHP | CC 47 | motor fail to start | power and control made off and on | 07:05:00 | 07:10:00 | |
| 5 | CHP | CC 45 | motor stop due to BS | mechanical adjusted belt | 07:25:00 | 07:35:00 | |
| 6 | CHP | CC 34 scr2 | LT not working,CAM switch common control supply missing , cable got cut | cable rejoined | 08:30:00 | 08:45:00 | |
| 7 | CHP | CC 104 SCR 9 | B/c not running,CJS acted,jamimng | informed operation | 09:30:00 | 09:40:00 | |
| 8 | CHP | CC 104 SCR 9 | B/C not running, | fault reset done than ok | 12:20:00 | 12:30:00 | |
| 9 | CHP | CC 34 SCR 2 | LT not taking place,OT acted | OT released | 11:40:00 | 11:50:00 | |
| 10 | WT | CC 3(c) | olr acted,mpcb tripped | mpcb made on | 11:45:00 | 11:50:00 | |
| 11 | IOSA | OLD WOBR | LT not taking place,end limit acted due to bushes | released | 08:15:00 | 08:30:00 | |