



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/02/2026

Area: IOSA

Equipment	Job
THRUSTER BRAKES	ONE THRUSTER BRAKE UNIT MADE READY AND CURRENTS AND OPERATION CHECKED,
IOSA-PLC	HARDWARE CONFIGURATION BACKUP TAKEN IN LAPTOP FOR OM-4, 1-142LC2 AND 1-142LC-3 RIO.
IOSA_ CPU B	GBC CARD REPLACED IN CPU-B .
1-28HVMCC - 5	BUS COUPLER MODULE AND PANEL DEFECT RECTIFICATION IN PROGRESS.
OC-2A	BRS UNIT MAINTENANCE DONE. FEEDBACK AND INTERLOCK CHECKING DONE.