



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/02/2026

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment                 | Problem                               | Action                 | From                 | To                   | Remarks |
|-------|------|---------------------------|---------------------------------------|------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO 26                     | OLR ACTED                             | RESET                  | 21:00:00             | 21:10:00             |         |
| 2     | CHP  | CC 219<br>RED             | C/S ACTED                             | INFORMED TO OPRN       | 15:30:00             | 15:40:00             |         |
| 3     | CHP  | SCR 6 ON<br>CC 39 LT      | M2 TRIP                               | MADE IT ON             | 15:30:00<br>21:15:00 | 15:40:00<br>21:25:00 |         |
| 4     | CHP  | SCR 6 ON<br>CC 39<br>SLEW | 30 DEGREE LIMIT ACTED                 | LIMIT RELEASED THEN OK | 20:10:00             | 20:20:00             |         |
| 5     | CHP  | SCR 1 ON<br>CC 34         | SLEW RIGHT LIMIT ACTED DUE TO JAMMING | INFORMED TO OPRN       | 21:30:00             | 21:40:00             |         |
| 6     | CHP  | CC 51                     | FEEDING CONVEYOR OLR ACTED            | RESET                  | 19:00:00             | 21:45:00             | 4 TIMES |
| 7     | CHP  | CC 54                     | OLR ACTED                             | RESET                  | 17:45:00             | 21:30:00             | 5 TIMES |