



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/05/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	Tripped on overload (3 times)	reset done	18:00:00 19:30:00 20:10:00	18:10:00 19:40:00 20:20:00	
2	OHP	CO 22 TBS	No drive starting	ACB in OFF condition , made on	18:20:00	18:35:00	
3	OHP	co 33a	brs bypass request due to belt hole	bypassed	17:00:00	17:10:00	
4	CHP	CC 54	Tripped in overload (2 times)	reset done	20:05:00	20:20:00	
5	WT	OP 5	M-5 Tripped on overload	Reset done	18:00:00	18:15:00	
6	WT	CO 3B	Electronic BRS bypassed	As per operation request	18:45:00	19:00:00	
7	IOSA	OC 2A	BRS kept in circuit	As per operation request	21:45:00	21:50:00	