



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 04/12/2025

Area: CHP

Equipment	Job
JH C 8,9,10	4 nos 120W fixtures provided
CC 32,34,42,44,45,46,48,49,105,SCR1,10,R1	Running inspection was done
CC 222/223	One 120W LED provided, 5 nos 70W fixtures mad ready for use
SCR 8	PCRD OT cam adjusted and kept in ckt
LC 5	Room cleaning under progress
CC 28,28TT,109,36,41,S 1,CC 55	PPM was done