



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 21/10/2025

Area: WT

Equipment	Job
CO 2 side	stair case lighting problem rectified
OT 4	200W LED fitting installed for visualization of clamp/ de clamp
OP 2	Panel side ppm including contactor core cleaning done
OP 2 and 5	After rake maintenance done