



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/05/2025

Area: IOSA

Equipment	Job
OC-3A	
UPS	ALL THE POWER AND INTERNAL CABLES CONNECTED.
OC-7A	MOTOR PROTECTION RELAY PARAMATRIZATION DONE AND CHECKED THE FUNCTION . IR VALUE CHECKED FOR CABLE & MOTOR.