



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/12/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-16	Reported ZSS acting	Checked and found wire came out of tb in MCC panel.Connected and tested okay	16:30:00	17:30:00	
2	OHP	BRC on CO-31	B/C not running	Stop PB contact not making at operator cabin.Made free and tested okay	17:10:00	17:20:00	
3	OHP	TBS on CO-7A	LT winding not taking place	Tension released and winding done and tested okay	19:30:00	20:20:00	NO delay
4	CHP	CC-51	Reported tripped	MPD tripped.Feeding conveyor stopped(7 times).Reset done	16:30:00	21:20:00	
5	CHP	CC 131	Reported tripped	OLR acted.Reset done(2 times)	19:20:00	21:27:00	
6	WT	OT-4	Reported tripped	Drive-2 tripped on PGEF-4 fault.Reset done	15:20:00	15:25:00	
7	WT	OT-3	Reported tripped	Drive-2 tripped on encoder fault.Control MCB found in off condition in brake panel.Made on	16:40:00	16:45:00	