



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/05/2025

Area: OHP

| Equipment | Job |
|-------------------------------|--|
| CO-5,6,7,1A | CJB and LDB PPM done |
| JH-3 cO-14,15,16 take-up area | lighting contactor replaced |
| CO-9A,11A | Lighting PJB preparation done. |
| CO-67,70 | Motor and panel PPM done |
| WOBR-1 ON CO-26 | Control and power cable rejoin done.LT end limit striker and welded and machine operation testing done |
| BRC-2 on Repair Bay | 22Kw CT motor shifted from Repair Bay to HVMCC-1 for overhauling |
| BRC-4 | Shifted from CO-8A to CO-34 |