



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/06/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR acted	reset done	00:15:00	00:20:00	
2	OHP	CO 6A WOBR	BC not running	Belt sway acted due to off centering . released , then ok	00:10:00	00:30:00	
3	OHP	CO 7	BRS kept in circuit	operation request	23:10:00	23:30:00	
4	CHP	CC 132	Tripped in overload	reset done	00:35:00	00:45:00	
5	CHP	CC 131	Tripped in overload	reset done	00:35:00 04:50:00	00:40:00 04:55:00	
6	CHP	CC 54	Tripped	reset	03:25:00 04:05:00	03:30:00 04:10:00	
7	CHP	CC 131	Not healthy due to pull cord acted	reset	00:35:00 22:35:00	00:40:00 22:45:00	
8	CHP	CC 35 , SCR 2	LT not working due to pcrd overtension	tension released	23:05:00	23:20:00	
9	WT	OP 6	Overtravelled to tippler side	reverse done with jumpers	00:00:00	00:20:00	
10	WT	OP 9	Not moving due to communication problem	power recycled	01:10:00	01:15:00	
11	IOSA	OC 9A	ZSS module problem from B shift	module changed and zss kept in circuit	22:40:00	23:40:00	