



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/05/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|---|----------------------------------|----------------------------------|---------------------------------------|
| 1 | OHP | RSCO 6A | Overload acted | reset done | 15:05:00 | 15:15:00 | |
| 2 | OHP | CO 57 | Stopped on pull chord | reset done | 16:15:00 | 16:30:00 | |
| 3 | OHP | TBS on CO 20 | Left Luff not working | Limit switch tied up , made free | 16:15:00 | 17:00:00 | |
| 4 | OHP | CO 33M | Pump not starting due to oil level low signal not coming | Sensor problem, bypassed as per instrumentation instruction | 17:30:00 | 18:00:00 | kept in circuit after sensor cleaning |
| 5 | CHP | CC 104 | Emergency push button acted | In IO rack termination loose , after re termination healthy | 15:00:00 | 15:15:00 | |
| 6 | CHP | CC 40 , SCR 6 | LT not working due to PCRD overtension | Overtension released | 17:20:00 | 17:30:00 | |
| 7 | CHP | CC 104, SCR 9 | LT not working due to PCRD overtension | Overtension released. | 17:00:00 | 18:00:00 | |
| 8 | CHP | CC 54 | Tripped in overload | reset done | 17:15:00 | 17:20:00 | |
| 9 | CHP | CC 131 | Tripped in overload | reset done | 16:40:00 20:10:00 21:20:00 | 16:45:00 20:15:00 21:25:00 | |
| 10 | CHP | CC 52 | Stopped on ZSS | Due to load on belt | 18:30:00 | 20:00:00 | |
| 11 | WT | OP 1 | Breaker tripped | Made ON and tested | 14:30:00 | 14:45:00 | Column no 74,75 |