



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/05/2025

Incharge(s): V Balaji Naik,G Eswara Rao

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--|--|----------------------|----------------------|---------|
| 1 | OHP | co 87 | reported fail to start/power contractor arc chute cover not fixed properly | fixed properly then ok | 18:45:00 | 19:10:00 | |
| 2 | OHP | co 35 | tripped on olr | reset done 2 times | 20:10:00 20:50:00 | 20:20:00 21:00:00 | |
| 3 | OHP | brc on co 33m | bw 1 not running/olr acted | reset done | 19:00:00 | 19:20:00 | |
| 4 | CHP | cc 36 | brs acting due to dust/sensors cleaning done | reset | 16:15:00 | 16:30:00 | |
| 5 | CHP | cc54 | tripped on olr | reset done | 17:20:00 | 17:30:00 | |
| 6 | CHP | cc 131 | tripped on olr | reset done | 17:30:00 | 17:35:00 | |
| 7 | CHP | scr 4 on cc 36 | It not taking place | under tension limit acted/reset done | 20:55:00 | 21:00:00 | |
| 8 | CHP | s1 on cc35 | It not taking place/pcrd cable drum not rotating | mech.gear box problem .informed to mech. and operation | 18:00:00 | 18:30:00 | |