



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	OT 3	DRIVE 1 TRIPPED	RESET	05:20:00	05:25:00	
2	OHP	CO 67	OLR ACTED	RESET	02:35:00	02:45:00	
3	OHP	CO 26	OLR ACTED	RESET	02:35:00	02:45:00	
4	CHP	SCR 6 ON C 38	B/C MOTOR	REPLACEMENT DONE	22:00:00	04:00:00	
5	CHP	CC 48	MECH BRS ACTED DUE TO BELT PIECE	CUT IT THEN OK	23:30:00	23:40:00	
6	CHP	SCR 1 ON CC 34	LUFF LIMIT ACTD	RELEASD	01:20:00	01:30:00	
7	CHP	SCR 1 ON CC 34	B/W OLR ACTED , SLEW DRIVE TRIPPED	RESET	04:30:00	04:45:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:00:00	06:00:00	8 TIMES
9	CHP	CC 54	OLR ACTED	RESET	05:50:00	05:55:00	