



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/11/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	OM-10	Reported all conveyors red	Checked and found control not there.MCB tripped in control transformer panel.Made on.	15:00:00	15:10:00	
2	OHP	CC125	Reported tripped	OLR acted.Reset done(2 times)	19:02:00	20:39:00	
3	OHP	CO-77	Reported tripped	OLR acted.Reset done	18:35:00	18:40:00	
4	OHP	BRC on CO-28	Reported LT not taking place	Checked and found Drive tripping on earth fault due to M5 motor cable fault.Rectified	17:40:00	18:00:00	
5	OHP	CO-24	Reported not running in local	Start button problem.Wire loose.Rectified	20:00:00	20:10:00	
6	OHP	Co-29	Reported tripped	OLR acted.Reset done	18:55:00	19:00:00	
7	OHP	Co-33M	Reported tripped	OLR acted.Reset done	19:20:00	19:25:00	
8	CHP	CC-53	Indication not coming to RG-3	Sensor cleaned and tested okay	19:35:00	19:45:00	
9	CHP	CC-52	Reported not running	Checked and found no drive position showing CCR.DOL mode bypassed in I/O rack and tested okay	19:50:00	20:10:00	
10	CHP	CC-24	Reported ZSS acting	Cage bearing problem.Bypassed due to demand.Cage replaced after demand	14:45:00	14:55:00	Bypass removed
11	CHP	CC-28	Reported TT not moving	MPCB tripped.Made on.	17:30:00	17:40:00	
12	CHP	CC28	indications showing on CC-31 and cc-33	Rectified	18:00:00	18:06:00	
13	CHP	CC105	Chute sensor acted.	Jamming found	16:40:00	17:00:00	Informed to operation
14	CHP	CC 39 SCR-1	LT reverse not working	joystick cable tightened and end limit released and tested okay	17:05:00	17:53:00	
15	CHP	CC-44	reported tripped	OLR acted.Reset done(4 times)	18:30:00	19:55:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC-32 R-1	Luffing down not working	Contactor stuck.Made free	19:20:00	19:35:00	
17	CHP	CC-54	Reported tripped	OLR acted.Reset done	20:20:00 20:35:00	20:25:00 20:40:00	
18	WT	OP-7	Selection not coming to OT-4	Checked and found MCB tripped in PLC panel of OT-4.Made on	15:55:00	16:00:00	
19	WT	CO-3	Reported tripped	OLR acted.Reset done	16:15:00	16:20:00	
20	IOSA	BRC	B/W not rotating	OLR acted.Reset done	21:35:00	21:45:00	