



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/07/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-58	MPCB TRIPPED	RESET DONE	08:00:00	08:10:00	
2	OHP	CO-87	TRIPPED ON OVER LOAD	RESET DONE	08:50:00	08:58:00	
3	OHP	TBS ON CO-7A	ACB TRIPPED	MADE ON	08:47:00	09:05:00	
4	OHP	CO-6A	ZSS NOT WORKING	MODULE SUPPLY WIRE LOOSE .. FIXED PROPERLY	08:35:00	09:00:00	
5	OHP	WBR ON CO-6A	BC NOT RUNNING	BELT SWAY ACTED DUE TO OFF CENTERING	10:50:00	11:05:00	
6	OHP	CO-3A	BRS BYPASS REQUEST DUE TO BELT OFF-CENTERING	DONE	12:00:00	12:15:00	
7	CHP	CC-35 SCR-1	BW NOT WORKING	OLR ACTED RESET DONE	10:00:00 10:50:00	10:05:00 11:05:00	
8	CHP	CC-52	TRIPPED ON OLR	RESET DONE	07:30:00 13:00:00	07:45:00 13:05:00	
9	CHP	CC-54	TRIPPED ON OLR	RESET DONE	09:30:00 10:30:00 11:00:00 12:30:00	09:35:00 10:35:00 11:05:00 12:35:00	
10	CHP	CO-38 SCR-3	BC STOPPING ON ZSS	CAGE STUCK ... MADE FREE	13:25:00	13:35:00	