



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 31	LT not taking place	M 6 tripped, reset done	15:00:00	15:20:00	
2	OHP	CO 15	ZSS probe wire cut	joint done	16:05:00	16:20:00	
3	OHP	CO 11 Carriage drive	MPCB tripped	made on	16:30:00	16:50:00	
4	OHP	CO 35	OLR acted	reset done	19:30:00	19:35:00	
5	OHP	CO 111	OLR acted	reset done	18:10:00	18:20:00	
6	OHP	CO 29	OLR acted	reset done	20:10:00	20:20:00	
7	OHP	TIS on CO 5	TIS not running	E PB acted , released	20:50:00	21:05:00	
8	CHP	CC 40 , SCR 3	Slew not working	jamming , informed to operation	16:00:00	16:10:00	
9	CHP	CC 24	Carriage drive not moving	Old joint problem , rejoint done	15:00:00	15:20:00	
10	CHP	CC 51	MPD tripped	reset	16:10:00	16:15:00	
11	CHP	CC 52	MPD tripped	reset done	17:55:00	18:00:00	
12	CHP	CC 54	Tripped on overload (5 times)	reset done	17:20:00	21:10:00	
13	CHP	CC 125	OLR acted	reset done	20:35:00	20:40:00	