



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 19/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS1A	olr acted	Reset done	22:15:00	22:25:00	
2	OHP	RSCO10a carriage drive	olr acted	Reset done	22:20:00	22:35:00	
3	OHP	BRC on CO34	Pump not working found oil level low	informed to operation and mechanical	23:13:00	23:35:00	
4	OHP	CO15	olr acted	reset done	05:25:00	05:30:00	
5	OHP	CO2a	ZSS not healthy found control fuse blown and control neutral wire opened	fuse replaced and neutral wire tightened	23:55:00	00:40:00	
6	OHP	RSCO9a	pull card not healthy	checked and found operated condition reset done	00:20:00	00:55:00	
7	OHP	BRC on CO31	bridge conveyor jammed and phase sequence reversed two times	after clearance normalised	23:45:00	00:00:00	01.00am to 01.45am
8	OHP	RCO1a	pull card not healthy	wrong complaint and found belts way acting frequently	00:45:00	00:55:00	
9	OHP	CO11 belt	olr acted	reset done	05:30:00	05:35:00	
10	OHP	Co2a	BRS not getting reset	mechanical BRS reset done	05:30:00	05:45:00	
11	OHP	TBS on CO22	BC not working found ZSS probe not working	Temporarily bypassed given clearance after that probe replaced found ok	00:10:00	00:20:00	ZSS probes not available
12	CHP	Cc28 flap gate	MPCB tripped on	Reset done	05:20:00	05:25:00	
13	CHP	CC51	MPD tripped on olr 5 times	Reset done	23:30:00	02:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 38 SCR 6	LT not taking place, drive trips in overload	drive reset	23:35:00	23:45:00	
15	CHP	CC 32 scr 5	LT not working, drive trips in overload	reset	00:20:00	00:30:00	
16	CHP	CC 40 scr 3	B/c not running, cjd acted, full jamming	informed operation	01:30:00	01:40:00	
17	CHP	CC 35 SCR1	LT not working, track jamming	informed operation	02:20:00	02:30:00	
18	CHP	CC 35	not running , gearbox oil low	informed operation	02:55:00	03:05:00	
19	CHP	CC 111 scr 8	boom conveyor not healthy, olr acted , olr mall functioning	olr reset, olr bypassed	04:40:00	04:50:00	May check olr further
20	WT	CO3 belt drive	Tripped due over load	Reset done	02:10:00 23:00:00	02:15:00 23:05:00	
21	WT	OT4	not rotating found D2 tripped twice on pgf1	reset done	05:00:00	05:05:00	
22	IOSA	TBS	End limit acted due to obstruction	Reset done	03:40:00	03:55:00	