



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 06/08/2025

Shift: B

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	Co 111 belt drive	mpcb trips due to overload	made it on	19:34:00	19:40:00	
2	OHP	WOBR on CO6a	Slewing not working due to charge pressure 2	Informed to mechanical (solenoid valve cleaned)	15:30:00	16:00:00	
3	OHP	TBS on CO21	LT not working found main control MCB tripped	Control MCB made on	17:00:00	17:10:00	
4	OHP	BRC on CO34	BW1 not working showing error in IO rake and High temperature in HMI in cabin	IO rake power recycled then ok	17:45:00	18:05:00	
5	OHP	CO16	reported red found over load acted due to jamming	Informed to operation and reset done	19:40:00	19:45:00	
6	OHP	CO35	Electronic over load acted	Reset done	19:40:00	19:45:00	
7	OHP	CO16	Electronic over load acted	Reset done	19:00:00	19:10:00	
8	CHP	S 1 on CC 38	slewing complaint, slew limit acted	reset and informed operator	15:00:00	15:10:00	
9	CHP	CC 31 R1	Lt not working, track jammed	informed operation	15:15:00	15:25:00	
10	CHP	CC201	olr acted	reset	15:40:00	15:50:00	
11	CHP	CC114	OLR tripped 2 times due to jamming	Reset done	19:00:00	19:10:00	08.30pm to 08.40pm: 09.40pm to 09.50pm
12	CHP	CC54	olr acted 2 times due to jamming	Reset done	18:05:00	18:15:00	
13	CHP	CT1 inhaul	over load trip	Reset done	21:30:00	21:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OC1A	Not running in healthy condition found full jamming motor rotating but belt not rotating and belt off centering also while starting FAIL TO START IN FWD	Checked at OC1A found jamming informed to operation	20:20:00	20:30:00	Not an electrical problem