



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/10/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-10A	TRIPPED ON OLR	RESET DONE	23:00:00	23:15:00	
2	OHP	BRC ON CO-31	BC TRIPPED ON OLR	RESET DONE	00:25:00	00:40:00	
3	OHP	TBS ON CO-7A	LBC NOT RUNNING	DUE TO MATERIAL JAMMING AND OFFCENTRING ... INFORMED OPERATION	02:05:00	02:15:00	
4	OHP	DB-1	TRIPPED ON OLR	RESET DONE	05:30:00	05:40:00	
5	CHP	CC-34 SCR-2	SIGNAL MISSING	LT DONE THEN OK	00:00:00	00:20:00	
6	CHP	CC-33 SCR-5	LT NOT WORKING .. PCRD OT ACTED	RELEASED	03:45:00	04:00:00	
7	CHP	CC-51	TRIPPED ON OLR	RESET DONE	01:40:00	01:45:00	
8	CHP	CC-54	TRIPPED ON OLR (4 TIMES)	RESET DONE	00:40:00	05:05:00	
9	CHP	VF-3	TRIPPED ON OLR	RESET DONE	23:40:00	23:45:00	
10	WT	OT-1	D1 TRIPPED ON PGF1 FAULT	RESET DONE	02:20:00	02:25:00	