



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/11/2025

Area: CHP

| Equipment | Job |
|--------------------|---|
| JH 8,9,10 | Hoist panels PPM was done |
| CC 222/223 | Belt Scale interlock analog card connections done, programming done for testing purpose |
| CC 25 | PPM was done |
| Coal complex,CM 17 | Rooms cleaning was done |
| SCR 2,3,6,7 | Instrumentation sensors maintenance was done |
| CC 213 High Mast | Mast lifted and installed,cables laid,lamp fixtures ring assembled and fixed |
| SCR 2 | PCRD resistance contactors replaced |
| S 1,SCR 2 | 2 nos machine shiftings were done |