



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/11/2025

Area: CHP

Equipment	Job
JH 8,9,10	Hoist panels PPM was done
CC 222/223	Belt Scale interlock analog card connections done, programming done for testing purpose
CC 25	PPM was done
Coal complex,CM 17	Rooms cleaning was done
SCR 2,3,6,7	Instrumentation sensors maintenance was done
CC 213 High Mast	Mast lifted and installed,cables laid,lamp fixtures ring assembled and fixed
SCR 2	PCRD resistance contactors replaced
S 1,SCR 2	2 nos machine shiftings were done