



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/08/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 2	tripped in olr	reset	16:20:00	16:30:00	
2	OHP	wobr 29	It not working,m4 olr acted	reset	15:10:00	15:30:00	
3	OHP	WOBR on co 29	b/c olr acted	reset	15:50:00 17:05:00 20:20:00	16:05:00 17:20:00 20:35:00	
4	OHP	CO 29	olr acted	reset	16:40:00	16:50:00	2 times
5	OHP	BRC on co 30	cabin side ct limit stucked	made released	17:15:00	17:30:00	
6	OHP	BRC on CO 30	LT not taking place,drives in hands on mode	change to auto on	18:00:00	18:15:00	
7	OHP	CO 35	olr acted	reset	19:45:00	19:50:00	
8	OHP	wobr on co 29	B/C not running,bc on PUSH BUTTON BROKEN AND GOT EARTHED,control wires in control desk and in boom conveyor panel got burn	on push button shifted to bypass button,control wires replaced and tested	21:20:00	22:20:00	push button to be provided
9	CHP	CC 51	olr acted	olr reset	16:20:00	16:25:00	
10	CHP	CC 114	olr acted	reset	19:59:00	20:05:00	
11	CHP	co 11(c)	mpcb trips	made it on	19:55:00	20:00:00	
12	CHP	CC 14	tripped in curt sp	reset it done	18:10:00	18:20:00	
13	CHP	CC 29 pos on cc 111	wire loose in i/o rack	cable properly fixed	21:15:00	21:30:00	
14	CHP	CC 126	cjd wire got cut	jointed	15:20:00	15:45:00	
15	CHP	CC33 scr 4	LT not working OT acted	OT released	16:15:00	16:25:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/08/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	cc 104 scr 9	slew not working,slew limit acted	limit released	16:45:00	17:10:00	
17	CHP	CC 32 SCR 5	LT not working,OT acted	OT released	17:00:00	17:20:00	
18	CHP	CC 32	tripped in olr	reset	17:15:00	17:25:00	
19	CHP	CC 223	not healthy,cjd acted	informed operation	21:30:00	21:55:00	
20	WT	co 3	zss acted,probe wire got cut	probe wire jointed	14:30:00	14:40:00	
21	WT	op1	no movement @coupling,d6 olr acted	olr reset	19:20:00	19:30:00	