



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/05/2025

Area: OHP

Equipment	Job
co-58 and rsco-9a	carriage drive movement is checked after clearing of jamming and currents were recorded.
JH O-3 shuttle conveyor level	illumination is improved near co-11,12,13
CO-31A,33A,35A	PPM done
co-3b h/e hoist	ppm is done
co-76r,4a	motor and panel ppm is done
WOBR-1 ON CO-26	Lighting rectified
BRC-4 ON CO-8A	HMI installation done
TBS-5	Shifted from CO-24 to CO-23
TBS	Yard interlock and boom ZSS inspection done
de-7	panel side incomer isolator is removed and made direct by using jumpers.
BRC-2 ON CO-28	PPM done
rsco-2a festoon cable	cable tray is welded in position and dressing of cables along the tray is done properly.