



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 25/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-26	TRIPPED ON OLR	RESET DONE	14:20:00	14:30:00	
2	OHP	BRC ON CO-31	BC NOT RUNNING DUE TO CHU SENSOR ACTED	CLEANED THEN OK	15:30:00	15:45:00	
3	OHP	CO-36A	CHUT SENSOR ACTED	SENSOR CLEANED	20:50:00	21:10:00	
4	OHP	CO-3A	STOPPED ON ZSS BECAUSE OF BELT SLOWING	SPEED SETTING INCREASED IN ZSS MODULE ON OPERATION REQUEST	18:00:00	18:20:00	
5	CHP	CC-29 BD	TRIPPED ON OLR	RESET DONE	17:30:00 20:00:00	17:35:00 20:10:00	
6	CHP	CC-104 SCR9	TUL CHUT SENSOR ACTING	CHUT JAMM .. INFORMED FOR CLEANING	16:25:00	16:35:00	
7	CHP	CC-45	TRIPPED ON OLR	RESET DONE	16:00:00 17:15:00	16:10:00 17:25:00	
8	CHP	CC-107	TRIPPED DUE TO OLR	RESET DONE	19:50:00	20:00:00	
9	CHP	CC-51	MPD TRIP ( 3TIMES )	RESET DONE	16:25:00	18:50:00	MPD MALF UNCTIONIN G TRIPPING IN UNDER CURRENT ... BYPASSED
10	CHP	CC-51	TRIPPED ON OLR 2 TIMES	RESET DONE	21:00:00	21:10:00	
11	CHP	CC-54	TRIPPED ON OLR	RESET DONE	18:16:00 18:25:00	18:20:00 18:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-51A	TRIPPED ON OLR	RESET DONE	18:59:00	19:05:00	
13	WT	OP-7	NOT MOVING	ES PRESSED IN CABIN ...RELEASED	16:45:00	16:50:00	