



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 22/11/2025

Shift: C

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-1A(C/D)	Reported tripped	OLR acted due to track jamming.Reset done	00:15:00	00:25:00	Informed to operation
2	OHP	CO-20	Reported ZSS acting	Probe damaged.Replaced and tested okay	01:00:00	01:20:00	
3	OHP	CO-12	Reported tripped	OLR acted.Reset done	01:30:00	01:35:00	
4	OHP	CO-29	Reported tripped	OLR acted.Reset done(3 times)	03:45:00	05:05:00	
5	OHP	BRC on CO-8A	B/W-2 not running	Mechanical problem	04:35:00	04:50:00	Informed to operation
6	CHP	Cc-8	Reported tripped	Control MCB tripped.Made on after tightening TB's and tested okay	00:10:00	00:20:00	
7	CHP	Cc-28	Reported tripped	OLR acted.Reset done	01:15:00	01:20:00	
8	CHP	CC-51	Reported tripped	MPD tripped.Reset done(4 times)	02:05:00	04:00:00	
9	CHP	CC131	Reported tripped	OLR acted.Reset done(2 times)	03:50:00	04:05:00	
10	CHP	Cc54	Reported tripped	OLR acted.Reset done(7 times)	02:25:00	05:05:00	
11	CHP	Cc 105 SCR 10	B/C not running	Fault reset done and tested okay	23:35:00	23:45:00	
12	CHP	Cc 39 SCR-2	Reported Slew not working	30 degree limit acted.Released and tested okay	00:38:00	00:51:00	
13	CHP	CC 104 SCR-9	Slew not working	Oil level low.	01:11:00	01:20:00	Informed to mechanical
14	CHP	CC 105 SCR 10	LT reverse not taking place	PCRD guide in jamming condition	01:30:00	01:42:00	Informed to operation



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/11/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC 105 SCR 10	B/C not running	TUL C/S acted due to jamming	05:16:00	05:27:00	Informed to operation