



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/10/2025

Area: WT

| Equipment | Job |
|------------------------|--|
| OP 10 | D3, direction tested and kept in circuit (9 nos ,35 sq lugs replaced) |
| OP 10 | D3, panel to motor cable found damaged,removed the damaged portion , |
| OP 10 | D3, motor TB removed and direct termination done |
| LC 10A | POE replaced ,dressing done and creepers removed @ Antina |
| OP 2 and 6, CP 1 and 4 | after rake maintenance done |