



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/07/2025

Area: OHP

Equipment	Job
wbr on co-25	LT m3 motor replaced and tested in dol mode. LT VFD drive failed , needs to be replaced.
brc-4 on co-34	ct reference checked, tightned ai card terminals and restored