



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/02/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 5A NO DRIVE RUNNING	CONTROL MADE ON	THEN OK	03:15:00	03:30:00	
2	OHP	CO 26	OLR ACTED	RESET	00:50:00	01:00:00	
3	OHP	TBS ON CO 20	LBC OLR ACTED	RESET	00:15:00	00:30:00	
4	OHP	BRC ON CO 32 LT	SKEW ACTING FREQUENTLY	INFORMED TO MECH	05:00:00	05:20:00	
5	CHP	SCR 2 ON CC 40	SLEW DRIVE TRIPPED	RESET	23:30:00	23:40:00	
6	CHP	CC 108	OLR ACTED	RESET	23:50:00	23:55:00	
7	CHP	CC 31	OLR ACTED	RESET	02:30:00	02:40:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:00:00	00:30:00	3 TIMES
9	CHP	CC 54	OLR ACTED	RESET	00:30:00	02:50:00	5 TIMES
10	CHP	CC 53	OLR ACTED	RESET	01:50:00 02:25:00	01:55:00 02:30:00	
11	CHP	CC 29	POSITION BIT ON CC 33	BYPASSED DUE TO STRIKER BENT	03:00:00	03:15:00	
12	WT	OT5	CONTROL MCB TRIPPED IN PLC PANEL AND ONE GLASS FUSE BLOWN	CONTROL MADE ON AND FUSE REPLACED	23:10:00	23:50:00	