



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/12/2025

Area: WT

| Equipment | Job |
|--------------|---|
| OP 1 | D4 motor changing alignment and testing done, removed motor shifted |
| OP 3,4 and 6 | After rake maintenance done |
| CO 2 level | Area lighting cable found cut ,10 mtrs cable laid and connected. |