



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/05/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR acted	reset done	22:50:00	23:00:00	
2	OHP	CO 34 , BRC	BW 1 is not rotating due to stone stuck up	Direction reversed , made free and given clearance	02:15:00	02:45:00	
3	OHP	CO 5 and CO 9	BRS bypass request from operation due to belt pieces	Bypassed as per operation request	02:30:00	02:40:00	At CJB
4	OHP	CO 26	OLR acted	reset done	04:20:00	04:35:00	
5	OHP	TT 3 on BPC 1	Signal not coming due to plug loose	Fixed properly	05:10:00	05:30:00	
6	OHP	CO 13 carriage drive	MPCB tripped	Made ON	01:30:00	01:40:00	
7	CHP	cc 33 , scr 4	Reported BW not running	Mains ON done in operator cabin	23:35:00	23:44:00	
8	CHP	CC 44	BRS to be bypass as per operation request	Bypass done	01:20:00	01:30:00	again kept in circuit
9	CHP	CC 32 , SCR 5	BC not running	OLR acted , reset done	01:40:00	01:50:00	
10	CHP	CC 38 , SCR 3	BC not running	Control MCB tripped , made on . Also TUL chute sensor kept in circuit	01:40:00	02:00:00	
11	CHP	CC 36 , SCR 1	BC signal missing	PLC recycled	00:40:00	01:00:00	
12	CHP	CC 33	Not running in remote mode	Stopping due to CC 51 overload	00:00:00	00:30:00	
13	CHP	CC 54	Tripped in overload (5 times)	reset done	22:30:00	04:35:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/05/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 131	Tripped in overload	reset done	01:30:00	01:45:00	
15	CHP	CC 51	Stopped on Zero speed due to overload	Informed to mechanical and operation	01:20:00	01:30:00	
16	CHP	CC 219	Not starting	Emergency stop hardware contact not coming , bypassed in panel	01:00:00	02:00:00	
17	IOSA	OC 25A	Overload acted	reset done	01:10:00	01:30:00	