



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/12/2025

Area: IOSA

| Equipment | Job |
|-----------|---|
| OC-21A | FIELD DEVICES FEEDBACK CHECKING DONE. FEEDBACK CHECKED IN PLC AND HMI. |
| OC-21A | PPM DONE ON MOTOR. |
| OC-5A | LIGHTING CIRCUIT DEFECTS RECTIFIED AND PROVIDED LIGHT FITTINGS. |
| OC-36A | CONVEYOR GALLERY LIGHTING CIRCUIT DEFECTS RECTIFIED AND PROVIDED LIGHT FITTINGS |
| OC-13A | ONE ADDITIONAL LIGHT FITTING PROVIDED NEAR T/E OF OC-13A |
| OC-7B | PULL CHORD HARDWARE SIGNAL MISSING. RECTIFIED THE DEFECT AND KEPT IN CIRCUIT. |
| OC-27A | MOTOR PROTECTION RELAY PARAMETERS AND CONNECTIONS CHECKED |
| OC-9A | PPM DONE ON MOTOR AND FIELD DEVICES |