



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-25	tripped on olr	RESET DONE	02:00:00 22:55:00 23:20:00	02:10:00 23:00:00 23:30:00	
2	OHP	BRC ON CO-30	BC ZSS NOT IN PLACE	KEPT IN PLACE	01:45:00	02:00:00	
3	OHP	BRC ON CO-30	BC OLR ACTED	RESET DONE	04:36:00	04:45:00	
4	OHP	BRC ON CO 8A	ACB TRIPPED	RELEASED	04:00:00	04:15:00	
5	OHP	CO-26	OLR ACTED	RESET	04:10:00	04:15:00	
6	OHP	BRC ON CO-34	LT NOT WORKING OT ACTED PCRD	RELEASED ... GUIDE ADJUSTED	23:10:00	23:25:00	
7	CHP	CC-47	FAIL TO START	CONTROL RECYCLE AND TESTED	23:20:00	23:33:00	
8	CHP	CC-104 SCR -9	LT NOT WORKING PCRD OT ACTED	RELEASED	23:30:00	23:45:00	
9	CHP	CC-39 S-1	LT NOT WORKING DRIVE TRIPPED	RESET	03:26:00	03:40:00	
10	CHP	CC-51	TRIPPED ON MPD	RESET	00:20:00 00:50:00	00:25:00 00:55:00	
11	CHP	CC-55	TRIPPED ON OLR	RESET DONE	00:30:00	00:40:00	
12	CHP	CC-58	TRIPPED ON OLR 3 TIMES	RESET DONE	00:40:00	01:05:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	IOSA	oc-27a	MOTOR PROTECTION TRIPPING	RESET DONE	22:30:00	06:00:00	DECK SHEETS FULL JAM INFORMED OPERATION (NO ELECTRICAL PROBLEM)