



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/12/2025

Area: WT

| Equipment | Job |
|------------------|---|
| OT 4 | Motor 1 removed for mechanical job and placed again after clarence and tested |
| OP 6 | Panel and Motor side ppm done,D3 and D6 lugs replaced one in each TB |
| OP 1 | Anti collision sensor connected after attaching dummy wagons and tested |
| OP 1,2,3,5 and 7 | After rake maintenance done |