



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/06/2025

Area: CHP

Equipment	Job
CC 222/223 gallery	Lighting ckt problems rectified and improved lighting
CC 27 ZSS	Module shifted to near zss cage and tested
CC 28,109,110,33,SCR 4	PPM was done
SCR 6	Cable chamber material cleaning done
R 1	PCRD OT limit adjusted and kept in ckt
SCR 2	Reclaiming mode cage interlock provided