



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/12/2025

Area: IOSA

Equipment	Job
OJH-4B	HOIST MOTOR SHIFTED TO OC-7A HEAD END PLATFORM.
TIPPLER GALLERY	PPM DONE ON ELECTRICAL HOIST PANEL AND MOTOR
MOTOR VIBRATION	MOTOR VIBRATION READINGS RECORDED FOR OC-31A, OC-33A, OC-36A, OC-37A.
OC-29A	INSPECTION DONE ON FIELD DEVICES.
OC-23A	GALLERY LIGHTING CIRCUIT DEFECTS RECTIFIED. LIGHT FITTINGS TO BE PROVIDED.