



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/07/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|-------------------------|----------------------|----------------------|---------|
| 1 | OHP | CO 3A | HEALTHY STOPPING POSITION INDICATION PLUG DAMAGED | PLUG REPLASD | 06:30:00 | 06:45:00 | |
| 2 | OHP | TBS ON CO 20 | L/LUFF NOT TAKING PLACE BRAKE PROBLEM | BRAKE ADJUSTED THAN OK | 09:00:00 | 09:15:00 | |
| 3 | OHP | BRC ON CO 34 | B/C NOT RUNNING SELECTOR LOCAL MODE IN OPERATOR CABIN | KEPT IN REMOTE | 09:30:00 | 09:50:00 | |
| 4 | OHP | BRC ON CO 33M | NO POWER CHECKED E/STOP ACTED | RESET | 13:30:00 | 13:45:00 | |
| 5 | CHP | CC 26 F/G | MPCB TRIPPED | MADE ON | 07:10:00 | 07:30:00 | |
| 6 | CHP | CC 19 | OLR ACTED | RESET | 10:05:00 | 10:15:00 | |
| 7 | CHP | CC 131 | OLR ACTED | RESET | 13:00:00 | 13:10:00 | |
| 8 | CHP | CC 54 | OLR ACTED(4TIMES) | RESET | 07:50:00 | 08:40:00 | |
| 9 | CHP | CC 111 S3 | B/C NOT RUNNING MOD TRIP | RESET | 06:30:00 | 06:40:00 | |
| 10 | CHP | CC 33 SCR 4 | LT NOT TAKING PLACE PCRD O/T ACTED | RELEASED | 09:30:00 12:30:00 | 09:40:00 12:40:00 | |
| 11 | CHP | CC 35 SCR 1 | LT NOT TAKING PLACE DRIVE TRIP | RESET | 09:40:00 | 09:50:00 | |
| 12 | CHP | CC 111 | BRS ACTING FREQUENTLY | SENSOR CLEANING THAN OK | 09:50:00 | 10:00:00 | |
| 13 | CHP | CC 32 SCR 5 | LT NOT TAKING PLACE M3 MPCB TRIP | RESET | 10:55:00 12:00:00 | 11:10:00 12:10:00 | |
| 14 | CHP | CC 125 | MPD TRIP | RESET | 11:00:00 | 11:05:00 | |
| 15 | WT | OP 2 | D 5 OLR ACTED | RESET | 13:20:00 | 13:40:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/07/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|---|----------------------------------|----------|----------|---------|
| 16 | WT | OT1 | NOT COMMING INTIONAL POSITION | LIMIT ADJUSTED | 07:30:00 | 08:00:00 | |
| 17 | WT | OP 2 | NOT MOVING F AND R PARKING ZONE CONTACTOR NOT PICK UP | TEMPRARY BY PASSED AGAIN REMOVED | 07:30:00 | 08:00:00 | |
| 18 | IOSA | WOBR ON OC 18A | LT NOT TAKING PLACE END LIMIT ACTED DUE TO GRASS | RELEASED | 13:30:00 | 13:45:00 | |
| 19 | IOSA | WOBR ON OC18A | SLEW AND B/W NOT WORKING RF1 OIL LEVEL ACTEDD | LEVER RESET | 06:30:00 | 07:30:00 | |