



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 31	b/c olr acted	reset	16:00:00	16:15:00	
2	OHP	CR 1	MPR tripped	reset	17:30:00	17:40:00	2 times
3	OHP	CO 26	OLr acted	reset	20:50:00	20:58:00	
4	OHP	CO 77	olr acted	reset	19:40:00	19:50:00	
5	OHP	co 31	bw 2 not running,olr acted	reset	21:50:00	22:00:00	
6	CHP	cc 31 scr4	LT not working,Ot acted,PCRD cable fell down	pcrd winding done	14:40:00	15:00:00	
7	CHP	CC 32	olr acted	reset	15:20:00	15:30:00	
8	CHP	CC 35 SCR3	b/c not running,zss cage problem,	cage fixed properly	15:40:00	16:00:00	
9	CHP	CC 33 R1	b/c not running,zss cage stone stucked	removed	17:45:00	18:00:00	
10	CHP	CC 50	ZSS acted, sensor cable loose connection	tightened	20:30:00	20:40:00	
11	CHP	CC 54	olr acted	reset	17:40:00	17:45:00	