



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 31/07/2025

Area: OHP

Equipment	Job
1-141lc3	incomer 2 is made on and bus-coupler kept off.
1-14lc7 and lc8	incomer 2 made on and bus-coupler kept off
TBS ON CO 23, TBS ON CO 21	RUNNNIG INSPECTION DONE
BRC ON CO 34	FUSED TBS PROVIDED FOR RTD supply at IO rack
TBS ON CO 19, CO-19	PPM COMPLETED
DE 21 Fan Y PHASE LUGS	damaged, to be changed.
CO 1A	BRS KEPT IN CIRCUIT
CO 6 ,	BRS KEPT IN CIRCUIT
CC-17 CC-24	PPM BOTH PANEL SIDE AND MOTOR SIDE DONE
JH-14 , BPC-1, BPC-2, CO 27A, CO 30A	HOIST PPM DONE
CO 59,60, 61	MOTOR GREASING DONE
1-141LC-3 I/O RACK	unused cables dressing is under process.
TBS-6	SHIFTED TO CO-24 from co-7a