



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/02/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC-54	OLR ACTED (3TIMES)	RESET DONE	09:20:00	10:35:00	
2	CHP	CC-131	OLR ACTED	RESET DONE	10:30:00	10:35:00	